

Olsson Associates
Consulting Engineers
1111 Lincoln Mall
Lincoln, Nebraska
January 5, 2007

ADDENDUM NO. 1

Densmore Park Backstop Replacement - 2006
Lincoln Parks and Recreation
Specification No. 07-003
OA Project No. 2006-1639

TO ALL WHO HAVE RECEIVED PLANS AND SPECIFICATIONS FOR THE REFERENCED PROJECT.

SCOPE

This Addendum covers the following additions, modifications, and clarifications to the Drawings and Specifications for this project.

SPECIFICATIONS

1. Refer to SECTION 02821 - CHAIN LINK FENCES AND GATES.
 - a. Refer to Part 2 PRODUCTS, Article 2.2 - INDUSTRIAL FENCE FRAMING, A. Delete the first sentence and replace with "Vertical round steel pipe posts shall conform to ASTM A53, Type E, Grade B and as shown on the drawings."

Each Bidder must acknowledge receipt of all addenda in the space provided on the Proposal form.