

ADDENDUM NO. 3

EXECUTIVE ORDER NO.79443
WATERFORD ESTATES 24-INCH TRUNK SEWER
SPEC. NO. 07-294

TO ALL PROSPECTIVE BIDDERS:

SUBJECT: Waterford Estates 24" Trunk Sewer

The 24" sanitary sewer will connect to a stub-out from the project to build the 30" sanitary sewer Executive Order No. 78974. Both projects will be bid on the same day and are tied (one contractor for both projects). The pipe material is not known at this time. Provisions in the project (General Note No. 13, Sheet 2 of the plans) require pipe materials to be the same between the manholes, so a transition coupling would not be permitted.

