

ADDENDUM NO. 1

EXECUTIVE ORDER NO. 78326  
SPEC. NO. 07-106  
WATER MAIN IN SOUTH FOLSOM

TO ALL PROSPECTIVE BIDDERS:

The ductile iron pipe in the 1440 ft directional bore shall be polywrapped. According to a representative of the Ductile Iron pipe Research Association, there is a written procedure for wrapping ductile iron pipe in a long directional bore.

Please sign and fax this cover sheet to Mary Lowe in Engineering Services at (402)441-6576 as receipt of receiving this Addendum, failure to do so could result in your bid being rejected.

\_\_\_\_\_  
Contractor

